

1.	Unique identification code of the product-type	FDMA
2.	Products	Dampers – Fire dampers
	Intended use	Fire safety. To be used in conjunction with partitions to maintain fire compartments in heating, ventilating and air conditioning installations.
	Technical documentation – product information, instruction for installation and maintenance, safety information	Technical specifications TPM 018/01
3.	Manufacturer	MANDÍK, a.s. Dobříšská 550, 26724 Hostomice, Czech Republic ID 26718405, tel. +420 311 706 706 mandik@mandik.cz , www.mandik.com
5.	System of AVCP	System 1
6.	Harmonised standard	EN 15650:2010
	Notified body	Notified body No. 1391 PAVUS, a.s., Prosecká 412/74, 190 00 Praha 9 – Prosek
	Output documents of the notified body	Certificate of Constancy of Performance No. 1391-CPR-2022/0033 Assessment Report of Performance of Construction Product No. P-1391-CPR-2022/0033

7a. Declared performances – fire resistance classification			
Essential characteristics in accordance with EN 15650:2010, art. 4.1.1			
<i>Fire separating construction, location of the damper</i>	<i>Installation type, installation system</i>	<i>Gap width (mm)</i>	<i>Performance – class of fire resistance</i>
Standard low- and high-density rigid wall construction according to EN 1363-1 – damper in the wall – 100 mm min. wall thickness	Mortar or gypsum ¹⁾	50–150	EI 90 (ve i↔o) S
	Mineral wool with fire protection mastic and cement lime plate ¹⁾	40–75	
	Ablative coated batt ¹⁾	50–200	
Standard low- and high-density rigid wall construction according to EN 1363-1 – damper remote from the wall – 100 mm min. wall thickness	Insulation of the duct with mineral wool ISOVER ULTIMATE PROTECT th.80 mm + ablative coated batt ¹⁾	40–75	EI 60 (ve i↔o) S
	Insulation of the duct with Rockwool Conlit Ductrock EIS 90 th. 60 mm + mineral wool with fire-resistant coating and board ¹⁾	40–75	EI 90 (ve i↔o) S
Standard flexible wall construction, min. EI 90 according to EN 1363-1 – damper in the wall – 100 mm min. wall thickness	Mortar or gypsum ¹⁾	50–150	EI 90 (ve i↔o) S
	Mineral wool with fire protection mastic and cement lime plate ¹⁾	40–75	
	Ablative coated batt ¹⁾	50–200	
Standard flexible wall construction, min. EI 90 according to EN 1363-1 – damper remote from the wall – 100 mm min. wall thickness	Insulation of the duct with mineral wool ISOVER ULTIMATE PROTECT th.80 mm + ablative coated batt ¹⁾	40–75	EI 60 (ve i↔o) S
	Insulation of the duct with Rockwool Conlit Ductrock EIS 90 th. 60 mm + mineral wool with fire-resistant coating and board ¹⁾	40–75	EI 90 (ve i↔o) S

(table continues)

1) Refer to [Technical documentation](#) for the details of the installation type / installation system.

(continuation of the table)

<i>Fire separating construction, location of the damper</i>	<i>Installation type, installation system</i>	<i>Gap width (mm)</i>	<i>Performance – class of fire resistance</i>
Standard low- and high-density rigid floor construction according to EN 1366-2 – damper in the floor – 150 mm min. floor thickness	Mortar or gypsum ¹⁾	50–150	EI 90 (h _o i↔o) S
	Mineral wool with fire protection mastic and cement lime plate ¹⁾	40–75	
	Ablative coated batt ¹⁾	50–200	
Standard low- and high-density rigid floor construction according to EN 1366-2 – damper remote from the floor – 150 mm min. floor thickness	Insulation of the duct with Rockwool Conlit Ductrock EIS 90 th. 60 mm + mortar or gypsum ¹⁾	50–150	EI 90 (h _o i↔o) S

1) Refer to [Technical documentation](#) for the details of the installation type / installation system.

7b. Declared performances – essential characteristics		
<i>Essential characteristics</i>	<i>Requirements (provisions of the harmonised standard EN 15650:2010)</i>	<i>Performance (lever or class) / Compliance with the requirements</i>
Nominal activation conditions/sensitivity:	4.2.1.2	Conforms
– sensing element load bearing capacity	4.2.1.2.2	Conforms
– sensing element response temperature	4.2.1.2.3	Conforms
Response delay (response time): – closure time	4.2.1.3	Conforms
Operational reliability: – cycling	4.3.1, a)	50 cycles – conforms
Durability of response delay: – sensing element response to temperature and load bearing capacity	4.2.1.2.2 4.2.1.2.3	Conforms
Durability of operational reliability: – opening and closing cycle tests	4.3.3.2	10 000 + 100 + 100 cycles – conforms

The performance of the product identified above is in conformity with the set of declared performance/s.
This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

In Hostomice, 2026-04-24

Jan Mičan
CEO, Ppa
MANDÍK, a.s.

Declared performances – other characteristics		
<i>Characteristics</i>	<i>Technical standard</i>	<i>Performance (lever or class) / Compliance with the requirements</i>
Resistance against corrosion	EN 15650:2010, art. 4.2.2 EN 15650:2010, Annexe B	Conforms
Damper blade tightness	EN 1751:2024	Class 2
Damper casing tightness	EN 1751:2024	Class ATC 3 (old marking “C”)